



Leslie Barnes  
Pasadena Unified School District  
351 S Hudson Ave  
Pasadena, CA 91109

**Reference:** Sierra Madre Elementary School - Air Flow Assessment

Our team of experts, comprising of engineers, technicians and surveyors recently inspected Sierra Madre Elementary School. Our specific scope of work was to conduct a measurement of the outside air flow for each classroom with regard to current ASHRAE standards.

Outside air flow measurements were taken for thirty-nine (39) classrooms. All classrooms have sufficient outside air and the units bring the required outside air. In one room, it is recommended that the district upgrade an economizer.

Sincerely,

Jennifer Lee  
Enviser Service Department  
SCL# 1005262